

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSchechische REPUBLIC
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕХСКАЯ РЕПУБЛИКА

Pod lisem 129/2, 182 00 Praha 8, Terešova

CERTIFICATE

No.: 1230416

Product: Electrical Insulating Blanket

Type: EIP0-1,5x0

Rating: Class 0, Category A, Z

Ordering firm: BOGUMA, s. r. o.
Továrenská 314, 95611 Bošany, Slovakia

Manufacturer: BOGUMA, s. r. o.
Továrenská 314, 95611 Bošany, Slovakia

Trade mark:

The test results are stated in the test-report No.: 231949-01/01 of: 08.09.2023

The sample of the product was found to be in conformity with:

ČSN EN 60322:2010 (idt. IEC 61112:2009)

cl. 5.2.2, 5.2.3, 5.2.5, 5.3, 5.5.2, 5.5.3, 5.5.4, 5.6.2.2, 5.6.2.3, 5.6.4.2, 5.6.4.3, 5.7, 5.8.1, 5.8.2, 6.2, 6.4


Other data:

The validity of the certificate is limited to: 14.09.2026

15.09.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



231949-01