

Declaration of Conformity

Short circuit device earthing set, Intercable art. number: 24200

This article is listed in the ENEL table: EA0127

Short circuit current and time:
7.2 KA, 0.2 seconds (peak factor 2)

The device consists of:

Nr. 2 extra-flexible copper strings section. 16 mm² length of 0.6 and 0.75 meters covered with transparent silicone sheath. Material with adequate flexibility, strength and mechanical elasticity. Compliant with CEI EN 61138 standard.

Nr. 4 Ø 8 mm expansion pins in copper alloy positioned at the two ends of the 600 and 750 mm long ropes. The expansion is carried out with the screw principle (steel screw) by acting on a resin knob. The pins are protected by a transparent plastic coating.

Nr. 1 short-circuiting terminal of the ropes positioned at the center of the 600 and 750 mm ropes with screw tightening. The clamp is made of copper alloy with a transparent plastic coating with a stopper cap.

According to the manufacturer's declaration, here we claim that the product is compliant with the standards:

- EN/CEI 60900
- EN/CEI 61230
- EN/CEI 10020
- IEC 228 - classe 6
- IEC 1138

Main Distribution
in the Central and Eastern Europe area:

Intercable CEEU Kft.
Magyar utca 162/A, HU 8800 Nagykanizsa

Intercable GmbH
Rienfeldstrasse 21, I-39031 Bruneck

The declaration is valid till revocation.

1st February 2023



INTERCABLE CEEU KFT.

H-8800 Nagykanizsa, Magyar u. 162/A.

Adószám: 13866587-2-20

VAT n.: HU13866587

